

C E R T I F I C A T E
of Conformity



Registration No.: AK 50393743 0001

Report No.: 50110654 001

Holder: **Sungrow Power Supply Co., Ltd.**
No.1699 Xiyou Rd., New & High
Technology Industrial
Development Zone,
Hefei 230088
P. R. China

Product: PV-Inverter
(Grid-connected PV Inverter)

Identification: Type Designation : SG125HV
Serial Number : Engineering Sample
Firmware Version : DSP_SG125KHV_V11_A
LCD_SG125KHV_V03_A_M
Remark(s) : Refer to test report 50110654 001
for details.

Tested acc. to: IEC 61727:2004
IEC 62116:2014
IEC 61000-3-11:2000
IEC 61000-3-12:2011

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Certification Body 
Zertifizierungsstelle
Weichun Li

Date 20.11.2017

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg